



CERTIFICATE

N₀ 1113119

The present certificate confirms that produced by

Pipelife Eesti Ltd

(address: Põrguvälja tee 4, Lehmja küla, Rae vald, 75301 Harjumaa, Estonia)

POLYETHYLENE PIPES FOR THE SUPPLY OF GASEOUS FUELS

made from material PE 100 and with the nominal dimensions those are given in following table 1 and with the standard dimension ratio SDR 11 conform to the standard ISO 4437:1997 *Buried polyethylene (PE) pipes for the supply of gaseous fuels – Metric series – Specifications – requirements.*

Table 1

| The nominal dimensions | | | |
|------------------------|----------------------|------------------------|----------------------|
| Outside diameter mm | Wall thickness mm | Outside diameter mm | Wall thickness mm |
| 32 | 3,0 | 110 | 10,0 |
| 40 | 3,7 | 125 | 11,4 |
| 50 | 4,6 | 160 | 14,6 |
| 63 | 5,8 | 200 | 18,2 |
| 75 | 6,8 | 225 | 20,5 |
| 90 | 8,2 | 250 | 22,7 |

This certificate presumes that Pipelife Eesti Ltd. follows continuously requirements of the above mentioned standard, operates consistently according to a implemented factory production control system those is documented, approved by the certification body Bureau Veritas. Also, according to the certification module the producer submits to the systematical surveillance those provide the periodical test of the product, inspection and evaluation of the factory production control system.

The certificate is based on the resolution N₀ 7 of 10 July 2009 of the certification body and on the results of the performed certification procedures.

Certificate is valid until 1 January 2012
Issued on 10 July 2009



Accreditation
PC021, I063



Tiit Hindreus
Country Manager