

Inspecta Estonia OÜ has granted a product certificate to attest that the product

PE corrugated double wall cable conduits for buried underground applications

placed on the market by

Pipelife Eesti AS

Põrguvälja tee 4, Lehmja küla, Rae vald, Harjumaa 75306, ESTONIA

and produced in the factory

Pipelife Eesti AS

Põrguvälja tee 4, Lehmja küla, Rae vald, Harjumaa 75306, ESTONIA

has following performances

Nominal outside diameter dn (mm)	Resistance to compression (N), (code):	Bending:
50	450	Pliable
50	450	Rigid
50	750	Rigid
75	450	Pliable
75	450	Rigid
75	750	Rigid
110	450	Pliable
110	450	Rigid
110	750	Rigid
110	1250	Rigid
160	450	Pliable
160	1250	Rigid

Product performances fulfil the requirements of standard **EN 61386-24:2010** and factory production control is implemented.

The manufacturer is testing the samples taken at the factory in accordance with prescribed test plan. Inspecta Estonia OÜ has performed type testing, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate is issued on **18.06.2014** and remains valid until **18.06.2019**, as long as the manufacturing conditions in the factory or the FPC itself are not modified significantly. The validity of the certificate can be checked on the Internet at www.inspecta.com.

Tallinn 12.09.2014

Tõnu Roosaar
Manager



Inspecta Estonia OÜ
Teaduspargi 8, 12618 Tallinn, Estonia
Tel +372 659 9470 Fax +372 659 9479
estonia@inspecta.com

Group headquarters: Inspecta Group Oy, Helsinki, Finland

TRUST & QUALITY www.inspecta.com